

Flexible flashing tape over flashing upstand

2.8x50mm hot dipped galvanised clout nails
in to framing. Staggered @ 300 centers.
(SS for Exposure Zone D)

16mm Single castellated timber head-batten
*See note

NC226

Impervious barrier between batten & cladding

Cavity closer as per E2/AS1
(By others)

NC134P

Pre-slotted base channel.
Providing 2000mm² of ventilation
per linear meter

5mm min gap

10mm min cover

Sealant for Very High to Extra High
wind zones.

Proprietary penetration seal by others

Continuous sealant on PEF backing
rod

Selected ventilation
cowl

Flexible flashing tape applied to soaker
and pipe

NC246

Neoprene sealant tape

NC248

Jamb flashing cap

NC247

Jamb flashing base.

Allow 6mm gap between vertical and
horizontal battens

NC227

Plastic soaker flashing. Base extends
down in to base channel.

Cavity batten note:

- 20mm single castellated timber battens required for all Nu-Wall installations.
- Batten to have 15° slope for moisture egress
- Allow 6mm gap between vertical and horizontal battens
- Sill and head battens to be max. 500mm with a 6mm gap to each segment
- 18mm single castellated battens are available from Nu Wall for all vertical applications to wall junctions and jams
- Proprietary Nu-Wall Alibat is available as an alternative when a structural non-combustable cavity batten is required

Stop-end tabbed up on
both sides of head
flashing

nu-wall
CLADDING

Nu-Wall cladding horizontal on cavity Typical large pipe penetration with cowl

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited

NW-HOC-022b.02

Drawn by: Nu-Wall

Date: 02/07/2025

Checked by: RL, GT

Scale: 1:2 @ A4

